

Annexure - I (A)

(ref. regulation 3.2, regulation 3.3)

Test Result Report
(Refer regulation 31 & 33 of CEA Safety Regulations, 2010)

(To be filled by representative of the Licensee)

Electricity Distribution Division: _____ Sub-Division: _____

Load applied (kW/kVA/HP) _____ Registration/Unique Application No.: _____

Nearest landmark Pole No./Feeder Pillar No. _____

Result of Insulation Resistance (to be measured on applying a pressure of 500 volts for one minute between phase conductor and earth) -

(i) Between Phase and Earth Phase-1 & Earth Phase-2 & Earth Phase-3 & Earth**Caution:** Insulation Resistance between phase and neutral or between phases shall not be measured when any of consumer's appliances, such as fans, tubes, bulbs, etc. is in circuit as results of such test would give resistance of appliance and not the insulation resistance of installation.

Certified that an Earth Terminal as required under Regulation 16 of CEA Safety Regulations, 2010 has been provided by UPCL and this terminal has been connected with UPCL's earthing system.

Following deficiencies have been found in your Electrical installation. You are requested to remove them within 15 days i.e. by _____ and inform UPCL, failing which your request for new connection would lapse:

1- _____

2- _____

Date: _____

Signature of Licensee representative**Name and Designation****(To be filled by Applicant)**

The testing of the premises has been carried out by Licensee in my presence and

*I am satisfied with the testing

*I am not satisfied with the testing and may file an appeal with Electrical Inspector

It is also certified that UPCL has*/has not* provided an Earth Terminal as per Regulation 16 of CEA Safety Regulations, 2010 at the premises and this earth terminal has*/has not* been connected to UPCL's earthing system.

Date _____

Signature of Applicant

* Strike out which is not applicable